



UNOKLIMA

VENTILATION

23-04-2025

Teknisk information

31032.20	UNOKLIMA 2.0 BASE 100	31033.20	UNOKLIMA 2.0 BASE 160
31034.20	UNOKLIMA 2.0 REMOTE 100	31035.20	UNOKLIMA 2.0 REMOTE 160
31040.20	UNOKLIMA 2.0 BATHROOM 100	31041.20	UNOKLIMA 2.0 BATHROOM 160
31042.20	UNOKLIMA 2.0 Wi-Fi 100	31043.20	UNOKLIMA 2.0 Wi-Fi 160
31044.20	UNOKLIMA 2.0 MULTI-ROOM 100	31045.20	UNOKLIMA 2.0 MULTI-ROOM 160

Klimair® Teknisk information		UNOKLIMA 2.0										UNOKLIMA XT	Klimair RE	
		31032.20	31033.20	31034.20	31035.20	31040.20	31041.20	31042.20	31043.20	31044.20	31045.20	31029.20	31030.20	31031.20
		BASE 100	BASE 160	REMOTE 100	REMOTE 160	BATHROOM 100	BATHROOM 160	WiFi 100	WiFi 160	MULTI- ROOM 100	MULTI- ROOM 160	REMOTE 160	REMOTE 100	REMOTE 160
V-Hz		220-240V 50Hz												
IP Klasse		X4												
Murtykkelse		250-500mm												
Støjreduktion ude/inde		<40dB										<41dB		
Max varmeeffekt v. opstart		<93%												
Gennemsnit varmeeffekt v.#2		EN Test: 100mm 83% - 160mm78%												
Driftstemperatur Celsius		-30 / +50												
Varmegenvindings cyklus		Ud 70 sekunder / Ind 70 sekunder												
		UNOKLIMA 2.0										UNOKLIMA XT	Klimair RE	
		31032.20	31033.20	31034.20	31035.20	31040.20	31041.20	31042.20	31043.20	31044.20	31045.20	31029.20	31030.20	31031.20
		BASE 100	BASE 160	REMOTE 100	REMOTE 160	BATHROOM 100	BATHROOM 160	WiFi 100	WiFi 160	MULTI- ROOM 100	MULTI- ROOM 160	REMOTE 160	REMOTE 100	REMOTE 160
Kapacitet M3/T	#Nat	-	-	5	10	-	-	5	10	-	-	10	5	10
	#1	10	20	10	20	10	20	10	20	10	20	20	10	20
	#2	20	40	20	40	20	40	20	40	20	40	40	20	40
	#3	30	60	30	60	30	60	30	60	30	60	60	30	60
Effekt Watt	#Nat	-	-	4,0	3,9	-	-	4,0	3,9	-	-	3,9	4,0	3,9
	#1	4,7	4,2	4,7	4,2	2,7	2,2	4,7	4,2	2,7	2,2	4,2	4,7	4,2
	#2	5,6	5,5	5,6	5,5	3,6	3,5	5,6	5,5	3,6	3,5	5,5	5,6	5,5
	#3	6,9	6,7	6,9	6,7	4,9	4,7	6,9	6,7	4,9	4,7	6,7	6,9	6,7
*Lyd dB(A) 3 mtr	#Nat	-	-	10	6	-	-	10	6	-	-	5	10	5
	#1	14	13	14	13	14	13	14	13	14	13	13	16	13
	#2	28	24	28	24	28	24	28	24	28	24	26	28	26
	#3	35	32	35	32	35	32	35	32	35	32	35	36	35
**Ventilationskapacitet rum M2	#Nat	-	-	3	7	-	-	3	7	-	-	7	3	7
	#1	7	14	7	14	7	14	7	14	7	14	14	7	14
	#2	14	28	14	28	14	28	14	28	14	28	28	14	28
	#3	20	40	20	40	20	40	20	40	20	40	40	20	40
***Gennemsnit varmeeffekt %	#Nat	-	-	NA	NA	-	-	NA	NA	-	-	NA	NA	NA
	#1	90	90	90	90	90	90	90	90	90	90	90	90	90
	#2	83	78	83	78	83	78	83	78	83	78	78	83	78
	#3	76	71	76	71	76	71	76	71	76	71	71	76	71
* Lyd ved udsugning. Der er forskel på lyden ved udsugning og ved indblæsning. Ved indblæsning er lyden lavere.						** Maksimal ventilation i rumstørrelse. Ved større rum installeres flere enheder.				*** Kalkuleret værdi ud fra EN Test v. #2				